



DIQQAT! Klapan ochiq holatga o'tgandan so'ng, hisoblagich gaz sizib chiqmayotganligini 6 daqiqa davomida 2 marta sinovdan o'tkazadi. Sinov davomida barcha gaz qurilmalari o'chirilgan holda bo'lishi kerak!